

## REFERENCES

1. Boustead, I., and G.F. Hancock, Handbook of Industrial Energy Analysis, pp. 220-252, Ellis Horwood Ltd., England, 1979.
2. Payne, G.A., The Energy Managers' Handbook, IPC Science and Technology Press, London, 2nd ed., 1980.
3. Dubin, F.S., H.L. Mindell, and S. Bloome, How to Save Energy and Cut Costs in Existing Industrial and Commercial Buildings, Noyes Data Corporation, New Jersey, 1976.
4. K S B Rose, "Energy Audit Series," Issued Jointly by the Department of Energy and Department of Industry, England, 1978.
5. Ottaviano, Victor B., Energy Management, Ottaviano Technical Services, New York, 1983.
6. "Energy Conservation Management," International Network on New and Renewable Energy Resources and Techniques for Asia and the Pacific, pp. 7-85, Energy Research and Development Center, Quezon City, Phillipines, 1986.
7. Kaya A., "Energy Management in Industry," E.G. Bailey Training Center, U.S.A., 1986.
8. Motoki Mutsuo, Electrical Energy Conservation Techniques, The Technological Promotion Association (Thai-Japan), Bangkok, 2 nd ed., 1984.
9. Yoshihiko Takamura, Thermal Energy Conservation Techniques, The Technological Promotion Association (Thai-Japan), Bangkok, 1 st ed., 1982.

10. Siriratanapanta, T., "An Analysis of Energy Flow for Conservation of Energy in Nakorn Chiang Mai Hospital," M.Eng Thesis, Department of Energy Technology, Asian Institute of Technology, 1983.
11. Teeraseranee, V., "Alternative Approaches for Energy Conservation in a Sanitary-ware Plant," M. Eng Thesis, Department of Industrial Engineering, Asian Institute of Technology, 1981.
12. Gochenour, Donald L., W.D. Wyant, and B.N. Windon. "Energy Audit Turns Up Many Opportunities For Energy Savings In Manufacturing Plant," *Industrial Engineering*, 46-52, 1981.
13. Carrier Air Conditioning Co., Handbook of Air Conditioning Design, McGraw-Hill Book Co., New York, 1965.
14. Eugene Stamper, Richard L. Koral, Handbook of Air Conditioning, Heating and Ventilating, Industrial Press Inc., New York, 3 rd ed., 1979.
15. ASHRAE, ASHRAE Handbook 1981 Fundamentals, The American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc., Atlanta, U.S.A., 3 rd Printing, 1982.
16. \_\_\_\_\_. ASHRAE Handbook 1982 Applications, The American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc., Atlanta, U.S.A., 2 nd Printing, 1983.
17. Hick, Tyler G., Standard Handbook of Engineering Calculations, McGraw-Hill, New York, 1972.
18. ASME, "Test Code for Steam Generating Units," The American Society of Mechanical Engineers, U.S.A, 1965.

19. Robert H. Perry and Cecil H. Chilton, Chemical Engineers'  
Handbook, pp. 6-29 to 6-34, McGraw-Hill, New York, 1973.
20. Roger G. Mote, "Jet Ejectors And Condensers As Vacuum Producing  
Devices," Ametek Schutte & Koerting Company, Inc., U.S.A.
21. Fondrk, V.V., "The Steam Jet Ejector: A Versatile Pump for High  
Vacuum," pp. 88, Proc. Fourth Nat. Symp. Amer. Vac. Soc.,  
Pergamon Press, U.S.A., 1958.
22. Suchai Sasivimonphand, Steam Technology, Association of Technology  
Promotion (Thai-Japan), Bangkok, 2 nd ed., 1980.
23. Gatts, Robert R., Robert G. Messey and John C. Robertson,  
"Energy Conservation Program Guide for Industry and  
Commerce, NBS Handbook 115," Department of Commerce,  
Washington, D.C., 1974.
24. Tawee Vechaputti, A Lecture Note on Air Conditioning Design,  
Chulalongkorn University, 1985.

APPENDIX A  
LAYOUT OF THE FACTORY




Figure A.1 Layout of the Factory





APPENDIX B  
ELECTRICAL ENERGY AUDIT

Table B.1 A Company-Wide Electrical Energy Audit (March 25, 1986)

Equipment	Nameplate		Measured			Hour per Day	kWh per Day	Remark
	HP	A	kW	A	V			
<u>Substation 1 for the Polymerization Section (1 st, 2 nd and 3 rd Floors)</u>								
1. Finish. Tower Heater	8x20.4*	8x40	81.6	14.2	-	24	1958	Run 4 sets
2. Extrus. Vapor. Heater	2x18*	2x36	24	26	-	24	576	Run 1-2 sets
3. Preheater	4x72*	4x143	120.9	412	-	24	2901	Dowterm
4. Transfer Heater	2x24*	2x48	31.2	66	-	24	749	Vaporizer
5. Monomer Tank Agitator	2x1.0	2x1.7	1.4	2x1.6	-	24	34	
6. Blend. Tank Agitator	1.0	1.7	0.7	1.6	-	8	6	
7. Monomer Transfer Pump	3x1.5	3x3.7	1.4	2x2.2	-	24	34	One standby
8. Quench Water Pump	2x5	2x8.4	1.8	5.4	389	24	43	One standby
9. Palletizer Drive	2x7.5	2x26	5	2x11.5	-	24	120	
10. Finish. Tower Drive	2x5	2x26	2.46	2x8.6	-	24	59	
11. Pull Roll Drive	2x .75	2x7.4	0.36	2x2.4	-	24	9	
12. Condensate Pump	1.0	3.3	0.45	2.0	-	10	5	
<u>Subtotal</u>			270			24	6494	kW= (6494)/24
<u>Substation 1 for the Spinning Section (3 rd Floor)</u>								

Table B.1 (Con't)

Equipment	Nameplate		Measured			Hour per Day	kWh per Day	Remark
	HP	A	kW	A	V			
13. Spinning Block Heater	6x24*	6x48	144	6x9	-	24	3456	
14. Spinning Manifold Heater	6x9*	6x18	54	6x13.6	-	24	1296	
15. Preheater Transformer	15kVA	22.5	51.5	-	-	24	-	
<u>Subtotal</u>			198			24	4752	
<u>Substation 1 for the Utility Section (1st Floor)</u>								
16. Condenser Pump-2 <sup>†</sup>	2x60	2x87	41.5	74.2	380	24	996	
17. Deep Well Pump <sup>†</sup>	2x40	2x60.5	24.8	43.6	375	20	496	
18. Boiler Water Feed Pump <sup>†</sup>	2x20	2x31	15	19	-	6	90	Start twice/min
19. Fuel Oil Feed Pump <sup>†</sup>	2x0.75	2x1.2	0.56	0.6	-	24	13	
20. Fuel Transfer Pump <sup>†</sup>	2x3	2x4.5	1.5	3	-	12	18	
21. Force Draft Fan <sup>†</sup>	2x7.5	2x22.5	1.09	7.53	383	24	26	
22. Condenser Pump-12 <sup>†</sup>	55	73.9	37.5	64.5	385	24	900	
<u>Subtotal</u>			106			24	2539	
<u>Substation 2 for the Spinning and Take Up Sections (1st, 2nd, and 3rd Floors)</u>								
23. Extruder Heater	6x35*	6x70	78.3	6x26.1	-	24	1880	
24. Extruder Drive	6x40	6x60	110.4	6x40.6	-	24	2650	

Table B.1 (Con't)

Equipment	Nameplate		Measured			kWh per Day	Hour per Day	Remark
	HP	A	kW	A	V			
25. Metering M/G Set	2x75	2x116	89.52	2x46	-	2148	24	
26. Godet M/G Set	2x40	2x69.4	47.8	2x32	-	1147	24	
27. Metering Inverter	75	129	44.8	30	-	1075	24	
28. Godet Inverter	40	91.2	23.87	11.3	-	573	24	
29. Silicone Circulate Pump	0.75	1.9	0.56	1.1	-	13	24	
30. Spinning ASWR Pump	2x15	2x23.6	16.12	15.83	383	386	24	
31. Quench Air Fan	60	82	35.8	62.7	-	859	24	
32. Take Up Air Fan	25	37.5	14.9	27.9	-	358	24	
33. Finish. Oil Agitator	0.25	0.5	0.19	0.5	-	5	24	
34. Finish. Oil Trans. Pump	3x0.75	3x1.5	1.68	3x1.1	-	40	24	
35. Emulsion Wheel Drive	3x0.5	3x2.5	1.12	3x1	-	27	24	
36. Finish. Oil Circ. Pump	0.75	1.5	1.12	1.3	-	27	24	
37. Finish. Oil Trans. Pump	2	3.4	1.5	1.2	-	36	24	
38. Fan Coil Unit	10	15	6.14	13.5	384	147	24	
39. Take Up Drive Transformer	4x45 kVA	274		4x32	-		24	
<u>Subtotal</u>			474			11371	24	
Substation 3 for the Draw-Twisting Section (1 st and 2 nd Floor)								

Table B.1 (Con't)

Equipment	Nameplate		Measured			Hour per Day	kWh per Day	Remark
	HP	A	kW	A	V			
40. Draw-twister 1-15	15x31.5	15x46.4	206	15x27.1	-	18	3708	Hour/day
41. Draw-twister 16-17	2x55	2x85	45.3	2x47	-	18	815	are based on data of
42. Back Winder	10	15	1.69	3.4	-	15	25	February 1986
43. Draw-twist. AWSR Fan	125	187	34.9	70	-	24	838	
44. Spray Water Pump	40	60	20.2	36.8	385	24	485	
<u>Subtotal</u>			245			24	5871	
<u>Substation 3 for the Polymerization Section</u>								
45. Aerator	2x20	2x30	13.8	25.5	387	12	166	One standby
46. Lift	20	-	8.9	-	-	6	54	
<u>Subtotal</u>			9			24	220	
<u>Substation 3 for the Spinning Section (3rd Floor)</u>								
47. Burn-out Blower 1	3	4.5	1.3	2.6	-	1	1.3	
48. Burn-out Blower 2	0.3	0.5	0.15	0.3	-	1	0.15	
49. Burn-out Heater	27*	54	14.88	37	-	1	14.88	
<u>Subtotal</u>			1			24	16	
<u>Substation 3 for Lighting</u>			57			24	1368	See Appendix C



Table B.1 (Con't)

Equipment	Nameplate		Measured			Hour per Day	kWh per Day	Remark
	HP	A	kW	A	V			
50. Delustering Pump	3	4.5	1.25	2.5	-	24	30	
51. Kady Mill	30	44.5	15.7	31.2	386	3	47	Run
52. Sand Mill Main Drive	15	24.1	4	8.5	-	3	12	4 times/wk
53. Delust. Mix Tank Agitator	0.25	0.5	0.08	0.2	-	3	2	5 hrs/run (7 a.m.-3 P.m.)
54. TiO <sub>2</sub> Transfer Pump	1.5	2.25	0.75	1.5	-	3	2	
55. Delust. Circ. Tank Agitator	0.25	0.5	0.08	0.2	-	24	2	
56. Dryers	4x20	4x30.8	13	4x9.7	-	15	195	25 min/bat.
57. Melting Tank Pump	5.5*	10.9	2.8	5.4	-	3	8	2 bat/shift
58. Blend. Transfer Pump	5.5*	10.9	1.5	3.0	-	3	5	
59. Raw Chip Trans. Blower	2x5	2x9.3	5.1	2x7.17	-	24	122	
60. Hot Well Pump	2x15	2x45	8.4	15.1	383	24	202	One standby
61. Chilled Water Pump-2 <sup>†</sup>	2x40	2x61	28.4	49.8	385	24	682	One standby
62. Miscut Chip Remover	2x1	2x1.5	1.26	2x1.27	-	24	30	
63. Raw Chip Rotary Feeder	2x0.75	2x1.7	1	2x1.6	-	24	24	
64. Monomer Recov. Feed Pump	2x3	2x5.35	1.1	2.5	391	24	26	One standby
65. CHPF <sup>†</sup>	5	8.5	2.1	4.8	-	24	50	

Table B.1 (Con't)

Equipment	Nameplate		Measured			Hour per Day	kWh per Day	Remark
	HP	A	KW	A	V			
66. Air Scrubber	1.5	2.8	0.48	1.2	-	24	12	
67. Dry Chip Trans. Blower	40	60.6	6.16	21.9	385	4	25	4 bat./day
68. Demineral. Water Pump	3	4.7	1.5	3.2	-	8	12	
69. Crush Mill	5	7.5	1.3	2.6	-	8	11	2-3 batches per shift
70. Lactam Exhaust Fan	0.75	1.5	0.45	1.2	-	8	4	One standby
71. Extract. Tower Lower Pump	3x3	3x5.35	1.2	2x2.8	-	24	29	
72. Monomer Circulate Pump	15	22.5	6.45	15.2	384	24	155	
73. Monomer Circulate Pump	2x10	15	5.5	11	-	24	132	One standby
74. Centrifuge Rotor	2x3	2x9	1.02	2x2.1	-	24	25	
75. Centrifuge Pusher	2x2	2x6	1.1	2x2.2	-	24	26	
76. Dry Chip Trans. Blower	10	17.5	4.77	11.2	-	12	57	
77. Monomer Recov. Water Pump	5	7.9	1.94	4.1	-	12	23	
78. Vacuum Pump	10	14.8	2.53	5	-	5	13	
79. Ext. Rotary Feeder	2x1.5	2x3.75	1.9	2x3.2	-	24	46	Ext. stands
80. Ext. Upper Pump	2	3.8	1.07	3.2	-	24	26	for Extraction
81. Ext. Upper Pump	3	4.7	1.57	3.4	-	24	38	Tower.
<u>Subtotal</u>			86			24	2071	

Table B.1 (Con't)

Equipment	Nameplate		Measured			Hour per Day	kWh per Day	Remark
	HP	A	kW	A	V			
<u>Substation 4 for the Office Building (1 st Floor)</u>								
82. Chiller Compressor	40	61	19.57	40.4	380	9	176	Office hour:
83. Chilled Water Pump	7	12.2	5.5	12.2	-	9	50	8 a.m.-5 p.m.
84. Condenser Pump	5	8.5	3.73	9.3	-	9	34	Sunday closed
85. Cooling Tower Fan	3	4.5	2.23	4.5	-	9	20	
<u>Subtotal</u>			10			24	280	$kWh = \frac{(280)(6)}{(24)(7)}$
<u>Substation 4 for the Utility Section</u>								
86. Demineral. Supply Pump	2x5	2x7.9	2.83	6	-	8	23	One standby
87. Chilled Water Pump 1-2**	2x10	2x15.8	7.59	13.52	382	24	182	One standby
88. Brine Chiller**	2x75	2x104	32.3	57.4	374	24	775	One standby
89. Brine Chiller**	100	143	44.7	102.2	383	24	1073	
90. Condenser Pump 1-2**	2x40	2x60	28.5	50.1	383	24	684	One standby
91. Cooling Tower Fan 1-2**	2x5	2x7.5	2.32	7.3	-	24	56	
92. Condenser Pump 12†	55	73.9	41.2	70.6	382	24	989	
93. Cooling Water Pump -1†	3	3.5	1.13	3.5	-	12	42	
94. Cooling Water Pump -2†	2	3	0.97	3	-	12	36	

Table B.1 (Con't)

Equipment	Nameplate		Measured			Hour per Day	kWh per Day	Remark
	HP	A	kW	A	V			
95. Cooling Tower Fan 21-22 <sup>†</sup>	2x20	2x60	28.29	49.7	387	24	679	
96. Air Compressor <sup>**</sup>	3x108	3x151	54.5	101.5	384	24	1308	Two standby
97. Centrifugal Chiller <sup>†</sup>	2x600	2x95	306	63	-	24	7344	3.3 kV
98. Cooling Tower Fan-1 <sup>†</sup>	25	58	3.15	10.1	-	24	76	
99. Chiller Transformer	2x2 kVA	6	-	-	-	2	-	One standby
100. Chem. Lab. Transformer	45 kVA	-	-	-	-	8	-	8 a.m.-4 p.m.
<u>Subtotal</u>			553			24	13,267	
<u>Grand-total</u>			2009			24	48,209	

\* The nameplate capacity is expressed in kilowatt.

\*\* See Figure 6.5 for the schematic illustration.

† This equipment possesses one standby.

‡ See Figure 6.1 for the schematic illustration.



APPENDIX C  
LIGHTING AUDIT  
Table C.1 A Company-Wide Lighting Audit (March 18, 1986)

Areas	No. of Lamp		Total Watts	Hour per Day	Measured Lux	CIE Std <sup>†</sup> Lux	Remark
	40W	** ES					
<u>Central Office Building</u>							
<u>Main Section</u>							
1. Plant Manager	2	-	106	8	300	500-750	Wattage of this
2. Typist	2	-	106	8	480	500	table is the wattage
3. Accountant	2	-	106	8	1200	500	of the lamp plus
4. Others	6	9	777	8	280-560	500	that of its ballast (approx. 13 W).
<u>Middle Section</u>							
5. Nursing Room	2	-	106	24	110	300	
6. Exec. Manager	2	4	310	8	880	500-750	
<u>Clerk Room</u>							
7. Front Zone	-	2	102	8	100	500	
8. Middle Zone	-	4	204	8	180	500	
9. Back Zone	-	8	408	8	230-360	500	
<u>Subtotal</u>	16	27	2225				kW (avg.) = 0.81 or 1.0
<u>Polymerization Building</u>							

Table C.1 (Con't)

Areas	No. of Lamp		Total Watts	Hour per Day	Measured Lux	CIE Std Lux	Remark
	40W	ES					
<u>1 st Floor</u>							
10. Work Shop	4	7	569	24	130-250	300-750	May off the unused
11. Toilet	1	-	53	24	97	100	
12. 1 st Row (East)	-	3 <sup>π</sup>	1200	12	50-100	150	
13. 2 nd Row	-	2	102	24	87-115	150	
14. 3 rd Row	2	1	157	12	80-130	150	
15. Screening	1	3	206	24	150	150	
16. TiO <sub>2</sub> Room	-	1	51	-	145	500	Uncertain time
17. 1000 kVA Tr. Rm.	6	-	318	12	130	150	
18. Security	-	2	102	12	200	150	
19. 4 th Row	1	4	257	24	145-155	150	
20. Laboratory	3	14	873	8	300-450	500	May off the unused.
21. Stairway 1-2	4	-	212	12	87	100	
22. Front Door	3	2	261	12	120	100	

Table C.1 (Con't)

Areas	No. of Lamp		Total Watts	Hour per Day	Measured Lux	CIE Std Lux	Remark
	40W	ES					
<u>2 nd Floor</u>							
23. Toilet	1	-	53	24	135	100	12 hrs is enough.
24. Lift Area	4	-	212	24	80	150	
25. Crush Mill	31	-	1643	4	450	300-500	
26. Cutter	18	5	1209	24	520	500	
27. Wet Chip	-	3 <sup>π</sup>	1200	12	250	150	
28. Air Washer	-	1 <sup>π</sup>	400	12	205	150	
<u>3 rd Floor</u>							
29. Extract. Tower	-	5 <sup>π</sup>	2000	12	312	300	
30. Instrument Room	1	9 <sup>π</sup>	3653	12	440-500	750	Local light. available
31. Control Room	1	5	308	24	160-550	500	
32. Heater Room	12	-	636	12	145	150	
33. Toilet	-	1	51	24	110	100	12 hrs is enough.

Table C.1 (Con't)

Areas	No. of Lamp		Total Watts	Hour per Day	Measured Lux	CIE Std Lux	Remark
	40W	** ES					
	<u>4 th Floor</u>						
34. Lift Area	1	1	104	12	87	150	
35. Extract. Tower	-	1 <sup>π</sup>	400	12	135	150	
36. Finish. Tower	-	1	51	12	98-166	150	
<u>5 th Floor</u>							
37. Lift Area	-	2	102	12	94	150	
38. Dry Chip	-	1 <sup>π</sup>	400	12	120	100	
<u>Subtotal</u>	94	51,23 <sup>π</sup>	16,783				kW(avg.) = 9.18 or 10.0
<u>Spinning and Take-Up Building</u>							
<u>1 st Floor</u>							
39. Toilet	-	5	255	24	100-280	150	2 may be removed
40. Corridor	2 <sup>*</sup>	2 <sup>*</sup>	92	24	97	100	
41. Take Up Room	8 <sup>*</sup>	158	8250	24	120-520	500	
42. Core Storage	-	9	459	24	33-89	30	3 may be removed



Table C.1 (Con't)

Areas	No. of Lamp		Total Watts	Hour per Day	Measured Lux	CIE Std Lux	Remark
	40W	ES					
<u>2 nd Floor</u>							
43. Spinning	15	36	1836	24	200-360	500-750	
44. M/G Set	4	5	467	24	30-345	150	
<u>Office</u>							
45. Yongyut-Vichai	-	4	204	18	145-280	500	Improvement is possible from both relamping and providing some more switches.
46. Adisorn	-	2	102	18	1150	500	
47. Nikom-Madam	-	3	153	18	370-505	500	
48. Corridor	7	3	524	24	100-200	100	
<u>3 rd Floor</u>							
49. Extruder	7	16	1187	24	80 <sup>III</sup>	100	Can be off by day
50. Beam Control	8	-	424	24	145-155	150-300	
51. Burn Out Room	-	4	164	6	70-150	150	
<u>Subtotal</u>	41,10*	245,2*	14,117				kw (avg.)=13.88 or 14.0
<u>Draw-Twisting Building</u>							

Table C.1 (Con't)

Areas	No. of Lamp		Total Watts	Hour per Day	Measured Lux	CIE Std Lux	Remark
	40W	ES					
52. Draw-twister	56	327	19645	24	200-500	300-750	
53. Pathway	13	13	1352	24	50-180	100	
54. Back Winder	1	10	563	24	200	500	
55. Box Storage	4	-	212	24	80	75	May be off by day
56. Textile Lab	10	19	1499	16	240-370	500	
57. Maintenance	1	14	767	8	220-400	500	
58. Packing	17	34	2635	24	150-240	300-500	May be off at night
<u>Subtotal</u>	102	417	26,673				kW(avg.)=25.66 or 26.0
<u>Utility Building</u>							
59. Boiler House	7	19	1340	12	167	150-300	
60. Chiller Room	17	9	1360	12	155	150-300	
61. Compressor Room	6	4	522	12	149	150-300	
62. Generator Room	12	-	636	12	135	150-300	
63. Repair. Shop	1	1	104	12	83	150-300	
64. Dining Room	1	10	563	12	120	150	

Table C.1 (Con't)

Areas	No. of Lamp		Total Watts	Hour per Day	Measured Lux	CIE Std Lux	Remark
	40W	ES					
65. Others	3	16	975	12	80	-	For securities, etc.
<u>Subtotal</u>	47	59	5500				kW (avg.) = 2.75 or 3.0
66. Dormitories	168	-	8904	8	-	-	kW (avg.) = 2.97 or 3.0
<u>Grand-total</u>	300	799	56649				kW (avg.) = 57.0

\* The wattage of this lamp is 20

\*\* "ES" is the lamp of energy saving type with a wattage of approx. 38 W.

† See Appendix D for more details.

π This is a high pressure sodium (HPS) lamp with a wattage of 400 each.

ππ Day lighting.

## APPENDIX D

Table D.1 Standard Service Illumination

Area/Activity	Standard Service Illuminance (lux)
<b>General building areas</b>	
Circulation areas, corridors	100
Stairs, escalators	150
Cloak rooms, toilets	150
Stores, stockrooms	150
<b>Assembly shops</b>	
Rough work: heavy machinery assembly	300
Medium work: engine assembly, vehicle body assembly	500
Fine work: electronic and office machinery assembly	750
Very fine work: instrument assembly	1500
<b>Textile industries</b>	
Bale breaking, carding, drawing	300
Spinning, winding, reeling, combing, dyeing	500
Beaming, spinning (fine counts), twisting, weaving	750
Sewing, burling, inspection	1000
<b>Clothing factories</b>	
Sewing	750
Inspection	1000
Pressing	500
<b>Offices</b>	
General offices, typing, computer rooms	500
Deep-plan general offices	750
Drawing offices	750
Conference rooms	500
<b>Homes and hotels</b>	
<i>Homes:</i>	
Bedrooms	
General	50
Bed-head	200
Bathrooms	
General	100
Shaving, make-up	500
Living-rooms	
General	100
Reading, Sewing	500
Stairs	100
Kitchens	
General	300
Working areas	500
Work room	300
Nursery	150

Source: International Commission for Illumination (CIE)



## APPENDIX E

### ENERGY SYSTEM MAINTENANCE PROGRAM

An effective maintenance program always pays off in lower energy costs, higher equipment availability and lower specific energy consumption. A successful maintenance program can generally be created by using a three-phase approach, including analysis, action, and monitoring.

The first phase, analysis, will consist the following steps:

1. Collect and analyze background data to find the total amount of potential energy cost saving. This step is considered as a process in the energy audit.

2. Examine each system to find where initial repairs can significantly decrease energy consumption and costs. The facility of this factory can be classified into eight major systems as shown in Table E.1. Portable instruments are necessary in this step.

Table 2.12 provides useful instruments for maintenance auditors.

In the selection of people to do the on-site inspection, line management personnel from each relevant area must be included because a maintenance audit by an external person will bring up questions that cannot be answered by anyone other than line personnel, and can also evaluate the operational feasibility of some suggestions at the time of the audit.

3. Estimate the cost and importance of major repairs.

4. List routine maintenance tasks along with times, frequencies, and skill and equipment requirements. The list, preferably on a 3x5

Table E.1 The Major Energy Systems for the Maintenance Program

System	Maintenance Activity
1. The Building Envelope (Outside wall and roof):	
Doors: Loose fitting	Weatherstripping
Do not close	Correct fit, check pressure
Windows: Air leakage	Weatherstrip, caulk
Broken	Replace panes
Walls: Cracks	Patch or seal
Roofs: Holes	Patch or cover
2. Boiler and Steam Distribution:	
Boiler: Safety problems	Correct immediately
Inoperable gauges	Overhaul
Stack gas problem	Check and adjust
Scale deposits	Fix water treatment
Steam traps leak	Repair or replace
Steam leaks	Repair
Steam line insulation ragged or	
missing	Repair or replace
Condensate return system	
uninsulated but hot	Insulate

Table E.1 (Con't)

System	Maintenance Activity
3. Ventilation and Air Conditioning System:	
Filter very dirty	Replace or clean
Damper blocked or disconnected	Repair linkage and check controls
Ductwork blocked inside	Examine and repair
Grillwork blocked or dirty	Remove blockage, clean
Fan motor not connected	Replace belts or disconnect motor
Thermostat reading not accurate	Calibrate and correct
4. Electrical System:	
Transformers:	
Leak	Replace immediately
Heat transfer surfaces fouled	Clean carefully
Contacts show burned spots	Repair immediately
Frayed wire	Tape carefully
Switch arc	Replace
5. Lights, Windows and Reflective Surfaces:	
Unused space illuminated	Remove lights or install better switches
Ballasts buzz	Adjust
Lights flicker	Replace or illuminate
Windows and lamps dirty	Clean and paint

Table E.1 (Con't)

System	Maintenance Activity
6. Air Compressors and Compressed  Compressor air leaks  Compressor oil leaks  Oil in pneumatic control system  Air line leaks	Air Distribution System:  Overhaul  Overhaul  Overhaul compressor  Repair
7. Manufacturing System:  Control not working  Working temperatures too high  Motor noisy  Motor hot	Overhaul  Study and correct  Check bearings  Adjust voltages on legs of three-phase input, correct belt tension
8. Material Handling Systems:  Excess use of diesel fuel  Uncontrol fuel use  Excessive tire wear  Excessive fuel use	Follow manufacturer's recommended procedures  Institute accounting of fuel per vehicle  Check tire pressure  Keep vehicles tuned up

inch card for each piece of equipment, should include such information as bearing identification numbers; fan belt, chain and pulley numbers and vendors; motor serial and model numbers; and any other information that would be required when the machinery needed to be repaired or replaced.

During the facility inspections, careful note should be made of all suggestions received. These suggestions form the basis of the action phase. The products of the analysis are 1) a list of all equipment in each system, 2) a list of major repairs needed to bring each system into working condition, 3) a collection of maintenance manuals, assembled in one place, and 4) a set of cards with the information needed for routine maintenance on each piece of equipment.

In action phase, goals for maintenance are chosen, repair actions are prioritized, money is allocated, people are assigned to specific projects and a schedule for major repairs is agreed upon. These steps should be performed by a team that includes representatives from plant engineering, line management, the comptroller and anyone else who either is known to have good information or represents an interest group within the company.

Goals for energy maintenance can be defined in terms of specific repair actions being performed, the number of systems that have shifted from repair to preventive maintenance, and a reduction in energy costs directly attributable to maintenance. In the process of choosing goals, the team needs to decide how and when progress toward these goals is to be measured.



Once the team has established goals for the maintenance program, possible projects must be prioritized. Criteria for assigning priorities include the following: survivability of the company, safety, compliance with government regulations and project economics.

People and funds can now be assigned to the chosen projects. A schedule can be established for progress and for reporting each project. A list of particular maintenance tasks to be performed each day should also be prepared at this stage.

The last phase, monitoring, is to determine progress toward the goals established in the action phase. In the case of preventive maintenance, the schedule of daily maintenance tasks must be checked periodically. These schedule must be reviewed at least once a year to include any new equipment, to compare repair records with maintenance tasks and to determine if some of the routine maintenance should be eliminated or expanded.

The result of this final phase is closure-completion of the project by analyzing expected gains against real gains. The reasons for any discrepancy can then be used as the start of another analysis, action, monitoring cycle, and the process repeats.

APPENDIX F

ENERGY AUDITS FOR THE CENTRAL AIR CONDITIONING SYSTEM

Table F.1 Energy Audit for the (Centrifugal Water Chiller) Air-Conditioning System (See Figure 6.1 thru 6.4 for More Details)

Item	Equipment	Nameplate		Actual			L.F. %	P.F. %	Hours per Day
		HP	A	kW	A	V			
1	Cent. Water Chiller	600	95	306 <sup>π</sup>	63	-	-	-	All Equipment Run 24 Hours
2	Transformer	2kVA	6	-	-	-	-	-	
3	Cooling Tower Fan-21	20	60	14.29	25.8	387	96	83	
4	Cooling Tower Fan-22	20	60	14	32.9	387	94	87	
5	Coondenser Pump-2	60	87	41.5	74.2	380	93	85	
6	Cooling Tower Fan-1	25	58	3.15*	10.1	-	-	-	
7	Condenser Pump-11	55	73.9	37.5	64.5	385	91	87	
8	Condenser Pump-12	55	73.9	41.2	70.6	382	100.4	88	
9	Chilled Water Pump-1	40	61	28.4	49.8	385	95	86	
10	CHPF	5	8.5	2.73*	5	-	-	-	
11	Hot Well Pump	15	22.5	8.4	15.1	383	75	84	
12	Quench Air Fan	60	82	34.3*	62.7	-	-	-	
13	Spinning AWSR Pump-1	15	23.6	8.06	15.83	383	72	77	
14	Spinning AWSR Pump-2	15	23.6	8.06	15.83	383	72	77	
15	Fan Coil Unit Blower	10	15	6.14	13.5	384	82	68	
16	Draw-Twist. AWSR Fan	125	187	38.2*	70	-	-	-	
17	Draw-Twist. AWSR Pump	40	60	20.2	36.8	385	68	82	
Total		1200	-	612.13			938.4	904	
Average							85.3	82.2	

Remark: Each of item 1,2,5,9, and 11 possesses one standby.

<sup>π</sup> This value is estimated based on PF = 0.85 and vottage of 3.3 kV.

\* This value is estimated based on PF = 0.83 and voltage = 380 V.

Table F.2 Energy Audit for the (Brine chiller) Air-Conditioning System

(See Figure 6.5 and 6.6 for More Details)

Item	Equipment	Nameplate		Actual			L.F. %	P.F. %	Hours per Day
		HP	A	KW	A	V			
1	Recip. Brine Chiller	75	104	32.3	57.4	374	58	87	All Equipment Run 24 Hours
2	Recip. Brine Chiller	100	143	44.7	102.2	383	60	66	
3	Cooling Tower Fan-1	5	7.5	1.0*	3.1	-	-	-	
4	Cooling Tower Fan-2	5	7.5	1.32*	4.2	-	-	-	
5	Condenser Pump	40	60	28.5	50.1	383	96	86	
6	Cooling Water Pump-1	3	3.5	1.13*	3.5	-	-	-	
7	Cooling Water Pump-2	2	3	0.969*	3	-	-	-	
8	Chilled Water Pump	10	15.8	7.59	13.52	382	101.7	85	
9	Cooling Air Fan	25	37.5	9.69*	30	-	-	-	
	Total	265		127.2					

Remark: Each of item 1, 5, and 8 possesses one standby.

\* This entry is estimated based on PF = 0.85 and voltage = 380 V.

Table F.3 Energy Audit for the Office Air Conditioning System

(See Figure 6.7 for More Details)

Item	Equipment	Nameplate		Actual			L.F. %	P.F. %	Hours per Day
		HP	A	kW	A	V			
1	Recip. Water Chiller	40	61	19.57	40.4	380	66	74	Run 9 Hours
2	Chilled Water Pump	7	12.2	5.22	12.2	-	100	-	
3	Condenser Pump	5	8.5	3.73	9.3	-	100	-	
4	Cooling Tower Fan	3	4.5	2.34	4.5	-	100	-	
	Total			30.86					

## APPENDIX G

### DETAILED CALCULATIONS FOR THE ANALYSIS OF AIR CONDITIONING SYSTEM

#### G.1 Calculations for the Analysis of the Draw-Twisting Building

The draw-twisting building is located within the manufacturing building group (see Appendix A) with the structure as illustrated in Figure 6.10. The process within this building space requires air-conditioning maintained at about 24°C (75.2°F) DB and 20°C (68°F) WB which is corresponding to the relative humidity of 70% (see Figure G.1 and Figure G.2).

Reduction of heat gain to the building space can be considered as follows:

1. Reduction of heat gain through the roof after installation of fiberglass.
2. Reduction of heat gain from the wall above this insulated ceiling.

#### 1. Reduction of Heat Gain Through the Roof

The coefficient of transmission, U, before installation of the ceiling can be computed as follows:

- |   |       |   |       |
|---|-------|---|-------|
| 1. Outside air film (15 mph wind),                      | $R_1$ | = | 0.17. |
| 2. Precast cement tile,                                 | $R_2$ | = | 1.30. |
| 3. 4"thick concrete, metal lath<br>and plaster ceiling, | $R_3$ | = | 2.50. |
| 4. Inside air film (still air),                         | $R_4$ | = | 0.68. |

Total thermal resistance,  $R_{T1} = 4.6$  or  $U_1 = 0.215$  Btu/  
(hr. ft<sup>2</sup> °F).





The U-value after installation of the ceiling can be computed as follows:

1. The existing thermal resistance,  $R_{T1} = 4.6$ .
2. 25 mm. thickness fiberglass,  $R_5 = 4.3^*$

Total thermal resistance after this proposal,  $R_{T2} = 8.9$  or  
 $U_2 = 0.112 \text{ Btu}/(\text{hr. ft}^2 \text{ }^\circ\text{F})$ .

It is noted that the U-value is reduced by  $0.103 \text{ Btu}/(\text{hr. ft}^2 \text{ }^\circ\text{F})$ .

The amount of heat gain through the roof is calculated by

$$Q = U.A. \Delta T_{eq}$$

where  $Q$  = the amount of heat gain, Btu per hour;

$U$  = coefficient of transmission,  $\text{Btu}/(\text{hr. ft}^2 \text{ }^\circ\text{F})$ ;

$A$  = roofing surface area, 29600 sq. ft;

$\Delta T_{eq}$  = equivalent temperature difference ( $^\circ\text{F}$ ), as given in Table

G.1.

Computations for the heat gain using the data described above are summarized in Table G.1. The reduction in heat gain after installing this insulated ceiling is the sum of  $Q_1$  (=3,487,471 Btu/day) minus the sum of  $Q_2$  (=1,816,729 Btu/day) which equals 1,670,742 Btu/day.


## 2. Reduction of Heat Gain from the Wall above the Insulated Ceiling.

The building under consideration is composed of four (4) sides of brick walls

The west wall is a boundary that separates the draw-twisting space from the take-up core storage room. Since the conditions of this

---

\*The value is provided by the manufacturer of this material.



G. LUFFT GmbH & Co. Postfach 692 D-7000 Stuttgart 1, Germany

Figure G.1 Control Chart for Temperature and Relative Humidity of the Draw-Twisting Space




Figure G.2  
**Carrier**<sup>®</sup>  
**PSYCHROMETRIC CHART**  
 Normal Temperatures

Copyright 1947 Carrier Corporation - Copyright 1978 Carrier Corporation - ACMS  
 Printed in U.S.A.  
 Coils (794-017)

Below 25 F, properties and saturation lines are for ice.

Table G.1 Calculations for Heat Gain Through the Roof of the Draw-Twisting Building

Item	SUN TIME																							
	AM												PM											
	6	7	8	9	10	11	12	1	2	3	4	5	6	7	8	9	10	11	12	1	2	3	4	5
$\Delta T_{eq}$	4	3	2	4	6	13	20	28	35	41	46	49	49	46	40	35	30	25	20	16	12	10	8	6
$Q_1$	25456	19092	12728	25456	38184	82732	127280	178192	222740	260924	292744	311836	311836	292744	254560	222740	190920	159100	127280	101824	76368	63640	50912	38184
$Q_2$	13261	9946	6630	13261	19891	43098	66304	92826	116032	135923	152499	162445	162445	152499	132608	116032	99456	82880	66304	53043	39782	33152	26522	19891
$(Q_1 - Q_2)$	12195	9146	6098	12195	18293	39634	60976	85366	106708	125001	140245	149391	149391	140245	121952	106708	91464	76220	50976	48781	36586	30488	24390	18293

- Remarks: 1. Heat Gain thru the Roof (Q), Btu/hr = U.A  $\Delta T_{eq}$ ,  $Q_1$  = without insulation and  $Q_2$  = with insulation.  
 2. The roof is assumed to have the weight of 20 lb/sq ft with the condition of "Exposed to the Sun."  
 3. The values of equivalent temperature difference ( $^{\circ}F$ ),  $\Delta T_{eq}$ , is developed for April & 14'N Latitude (24) which is applicable to Samutsakorn province.  
 4.  $Q_1 = (0.215)(29600)(\Delta T_{eq})$  and  $Q_2 = (0.112)(29600)(\Delta T_{eq})$   
 Source:  $\Delta T_{eq}$  values are taken from a lecture note on air conditioning design (24). see Table G.6.






Figure G.3 Plot of Heat Gain Through the Roof of the Draw-Twisting Building (See Table G.1)




two areas are almost the same, heat transfer through this wall is assumed to be zero.

The east wall is a common wall of the shipping warehouse and the draw-twisting building. This warehouse is a non-air-Conditioned space with the condition nearly the same as those of outside space. The wall area above the proposed ceiling is 100 square meters (50 m x 2m) or 1076 sq ft.

The north and south walls are exposed to outside space with the wall area above the ceiling of 110 square meters (55 m x 2m) or 1184 sq ft each.

Generally, shaded walls and north exposures have the same equivalent temperature difference (13). Hence, the north and east walls in this calculation are considered as a unique wall with the area of 2260 sq ft (1076 sq ft of the east wall plus 1184 sq ft of the north side.)

The existing walls are of double bricks with stramit board (insulation) inside. The transmission coefficient,  $U$ , in Btu per (hour) (sq ft) (deg F) can be computed as follows:



1. Outside air film (15 mph wind)  $R_1 = 0.17.$
  2. Double common brick, 8 in,  $k=5; R_2 = 1.60.$
  3. Stramit board (insulation)  $R_3 = 1.25.$
  4. Inside air film (still air)  $R_4 = 0.68.$
- Total thermal resistance,  $R_T = 3.7.$

Therefore, the U-value of these walls is 0.27

$$(U = 1/R_T).$$

The calculations for heat gain through walls are illustrated in Table G.2. To attain the total heat gain, we proceed as follows:

Heat gain thru the north and east (shade) walls is the sum of  $Q_{ns}$  in Table G.2 throughout the day (24 hours) = 104344 Btu/day.

Heat gain thru the south wall is the sum of  $Q_s$  in Table G.2 throughout the day (24 hours) = 91,429 Btu/day.

Hence, the total heat gain is  $104,344 + 91,429 = 195,773$  Btu/day.

After installation of the fiberglass ceiling, this wall area (above the ceiling) is considered as a component the roof. Therefore, the amount of heat gain of 195,773 Btu/day is blocked by the proposed ceiling.

According to the calculations given above, the total reduction of heat gain is the sum of heat gain through the roof reduced (1,670,742 Btu/day) and that amount blocked by the ceiling (195,773 Btu/day) which equals 1,866,515 Btu/day.

Table G.2 Calculations for Heat Gain Through Walls above the Proposed Ceiling

Item	SUN TIME																							
	AM												PM											
	6	7	8	9	10	11	12	1	2	3	4	5	6	7	8	9	10	11	12	1	2	3	4	5
$\Delta T_{eq}^{North}$ (Shade)	0.5	0.5	-0.5	-0.5	1.5	2.5	3.5	9.5	9.5	11.5	13.5	14.5	15.5	15.5	15.5	12.5	11.5	9.5	7.5	5.5	4.5	3.5	2.5	1.5
$Q_{ns}$	305	305	-305	-305	915	1526	2136	5797	5797	7017	8238	8848	9458	9458	7628	7017	5797	4577	3356	2746	2136	1526	915	
$\Delta T_{eq}^{South}$	2.5	0.5	-0.5	0.5	1.5	10.5	15.5	23.5	27.5	28.5	29.5	26.5	23.5	18.5	13.5	11.5	9.5	7.5	5.5	4.5	3.5	2.5	2.5	
$Q_{so}$	799	160	-160	160	480	3357	4955	7512	8791	9111	9431	8472	7512	5914	4316	3676	3037	2398	1758	1439	1439	1119	799	

- Remarks: 1. Heat Gain Through Walls ( $Q$ ), Btu/hr = U.A.  $\Delta T_{eq}$ ,  $Q_{ns}$  = thru north and east (shaded) walls, and  $Q_{so}$  = thru south wall.  
 2. The walls are assumed to be of 60 lb/sq ft.  
 3. The values of equivalent temperature difference ( $^{\circ}F$ ),  $\Delta T_{eq}$ , is developed for April & 14 $^{\circ}$ N Latitude (24) which is applicable to Samutsakorn province.  
 4.  $Q_{ns} = (0.27)(2260) (\Delta T_{eq}^{North})$  and  $Q_{so} = (0.27)(1184) \Delta T_{eq}^{South}$
- Source:  $\Delta T_{eq}$  values are taken from a lecture note on air conditioning design (24). see Table G.7.

Table G.3 Outdoor Conditions for the Peak Month (April)

Item	SUN TIME																							
	AM												PM											
	6	7	8	9	10.	11	12	1	2	3	4	5	6	7	8	9	10	11	12	1	2	3	4	5
DB Temp (°F)	78.0	78.7	79.9	82.7	85.0	88.8	90.9	92.5	93.5	93.9	93.7	93.0	91.3	89.4	87.3	85.4	83.6	82.9	81.4	80.2	79.5	79.0	78.6	78.3
WB Temp (°F)	76.0	76.5	76.9	78.8	79.9	80.8	81.2	82.0	82.0	82.1	81.6	81.1	80.6	80.2	79.5	78.9	78.5	77.6	77.2	77.0	76.8	76.7	76.7	
Enthalpy (Btu/lb of dry air)	39.6	40.1	40.5	42.5	43.6	44.5	45.0	45.9	45.9	46.0	45.4	44.9	44.3	43.9	43.1	42.5	42.1	42.1	41.2	40.8	40.6	40.4	40.3	

Remarks: 1. The temperatures, db and wb, are provided by the Grim Carrier Co., Ltd.

2. The values of enthalpy are found from the Psychrometric Chart (Copyright 1947 Carrier Corporation-Copyright 1959 Carrier Corporation-AC 467), see Figure G.2.

3. The average enthalpy = 42.729 Btu per pound of dry air.

Source: Temperatures are generated by a Carrier Computer Package.

Table G.4 Cooling Load Estimation for the office Rooms

SHEET _____ DATE _____					OFFICE <u>3 P.M.</u>					
PREPARED BY _____					PROP NO. _____ JOB NO. _____					
NAME OF JOB _____					APPROVED _____					
LOCATION <u>SAMUTSAKORN PROVINCE</u>										
SPACE USED FOR <u>MANAGEMENT &amp; PAPERWORK</u>					ESTIMATE FOR		PEAK LOAD		LOCAL TIME	
SIZE <u>49.2 x 82.02 x 4037</u> SQ FT x <u>9.84 x 39724</u> CU FT					LOCAL TIME		PEAK LOAD		LOCAL TIME	
ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	BTU/HOUR	EQUIPMENT OPERATION <u>g</u> HOURS/DAY					
SOLAR GAIN - GLASS					CONDITIONS	DB	WB	%RH	DP	GR/LB
GLASS E(1)	65	SQ FT x 13F	x .65	549	OUTDOOR (OA)	95	78	61	79.5	153
GLASS E(2)	97	SQ FT x 13F	x .65	820	ROOM (RM)	78	65	50	58	71
GLASS W(1)	200	SQ FT x 149F	x .65	19370	DIFFERENCE	17	xxx	xxx	xxx	82
GLASS W(2)	87	SQ FT x 149F	x .65	8426	Ventilation 19 PEOPLE x 10 CFM/PERSON = 190 4037 SQ FT x .15 CFM/SQ FT = 605 CFM VENTILATION = 605					
SKYLIGHT	-	SQ FT x -	x -	-	Infiltration SWINGING, REVOLVING DOORS _____ PEOPLE x _____ CFM/PERSON = _____ OPEN DOORS _____ DOORS x _____ CFM/DOOR = _____ EXHAUST FAN _____ CRACK _____ FEET x _____ CFM/FT = _____ CFM INFILTRATION = SEE NOTES					
SOLAR & TRANS. GAIN - WALLS & ROOF					APPARATUS DEWPOINT & DEHUMIDIFIED AIR QUANTITY					
WALL E(1+2)	647	SQ FT x 16.5F	x .46	4911	EFFECTIVE SENSIBLE HEAT FACTOR	148735	ERSH	0.68		
WALL W(1+2)	560	SQ FT x 35.5F	x .46	9145	INDICATED ADP = _____ F	SELECTED ADP = _____ F				
WALL N(1+2)	970	SQ FT x 15.5F	x .46	6916	(1 - _____ BF) x (T <sub>RM</sub> _____ F - T <sub>ADP</sub> _____ F) = _____ F 1.09 x _____ F <sub>DEHUM. RISE</sub> = _____ CFM <sub>DA</sub>					
WALL S(1+2)	728	SQ FT x 31.5F	x .46	10549	SUPPLY AIR QUANTITY RSH _____ FIRM-OUTLET AIR = _____ 1.09 x _____ CFM <sub>DA</sub> = _____ CFM <sub>SA</sub> F <sub>DESIRED DIFF.</sub> = _____ CFM <sub>BA</sub>					
ROOF - SUN	-	SQ FT x -	x -	-	*IF THIS ΔT IS TOO HIGH, DETERMINE SUPPLY CFM FOR DESIRED DIFFERENCE BY SUPPLY AIR QUANTITY FORMULA.					
ROOF - SHADED	-	SQ FT x -	x -	-	RESULTING ENT & LVG CONDITIONS AT APPARATUS T <sub>RM</sub> _____ F x _____ CFM <sub>DA</sub> x (T <sub>OA</sub> _____ F - T <sub>RM</sub> _____ F) = T <sub>EDB</sub> _____ F T <sub>ADP</sub> _____ F + _____ BF x (T <sub>EDB</sub> _____ F - T <sub>ADP</sub> _____ F) = T <sub>LDB</sub> _____ F FROM PSYCH CHART: T <sub>EWB</sub> _____ F, T <sub>LWB</sub> _____ F					
TRANS. GAIN - EXCEPT WALLS & ROOF					WHEN BYPASSING A MIXTURE OF OUTDOOR AND RETURN AIR, USE SUPPLY CFM. WHEN BYPASSING RETURN AIR ONLY, USE DEHUMIDIFIED CFM.					
ALL GLASS	692	SQ FT x 17F	x 1.0	11764	NOTES INFILTRATION = (HxLxWxG)/60 = 39724 x 1.5 / 60 = 993.4 USE 1000 CFM DOOR INFILTRATION = (DOOR OPENING/HR) x 100 / 60 DOOR OPENING = 2 TIMES/PERSON/HR ∴ TOTAL INFILTRATION = 1100 CFM					
PARTITION	-	SQ FT x -	x -	-						
CEILING	4037	SQ FT x 17F	x .3	20589						
FLOOR	-	SQ FT x -	x -	-						
INFILTRATION	1100	CFM x 17F	x 1.09	20388						
INTERNAL HEAT										
PEOPLE	19	x 215	x	4085						
POWER	-	HP OR KW x -	-	-						
LIGHTS	2225	WATTS x 1.25	x 34	9456						
APPLIANCES, ETC. (XEROX)	1500 W	x 3.4	x	5100						
ADDITIONAL HEAT GAINS	-	x -	-	-						
SUB TOTAL				132063						
STORAGE	-	SQ FT x -	x -	-						
SUB TOTAL				-						
SAFETY FACTOR	2			2641						
ROOM SENSIBLE HEAT (RSH) ■				134704						
SUPPLY DUCT HEAT GAIN	4	% SUPPLY DUCT LEAK LOSS	2	% FAN H.P.	4					
OUTDOOR AIR	605	CFM x 17 F	x .05 BF x 1.09	561						
EFFECTIVE ROOM SENSIBLE HEAT (ERSH) ■				148735						
LATENT HEAT										
INFILTRATION	1100	CFM x 82	GR/LB x 0.68	61336						
PEOPLE	19	x 235	x	4465						
STEAM	-	LB/HR x 1050	-	-						
APPLIANCES, ETC.	-	-	-	-						
ADDITIONAL HEAT GAINS	-	-	-	-						
VAPOR TRANS	-	SQ FT x 1/100 x -	GR/LB x -	-						
SUB TOTAL				65801						
SAFETY FACTOR	2			1316						
ROOM LATENT HEAT (RLH) ■				67117						
SUPPLY DUCT LEAKAGE LOSS	2			1342						
OUTDOOR AIR	605	CFM x 82	GR/LB x 0.68	1687						
EFFECTIVE ROOM LATENT HEAT (ERLH) ■				70146						
EFFECTIVE ROOM TOTAL HEAT (ERTH) ■				218881						
OUTDOOR AIR HEAT										
SENSIBLE	605	CFM x 17 F	x .05 BF x 1.09	10650						
LATENT	605	CFM x 82	GR/LB x 0.68	32048						
RETURN DUCT HEAT GAIN	-	% RSH	RETURN DUCT LEAKAGE GAIN	% RSH						
RETURN AIR OR BLOW THRU FAN	-	HP x 2545	-	2545						
GRAND TOTAL HEAT (GTH) OR DEHUMIDIFIER LOAD ■				264124						
PUMP HP	-	% GTH	PIPING HEAT GAIN	% GTH						
REFRIGERATION LOAD ■				22 TR						



Table G.5 SOLAR HEAT GAIN THRU ORDINARY GLASS Btu/(hr) (sq ft sash area)

13.8°N LAT

NORTH LATITUDE		SUN TIME											SOUTH LATITUDE				
Time of Year	Exposure	AM						PM					Exposure	Time of Year			
		6	7	8	9	10	11	Noon	1	2	3	4			5	6	
Aug. 24 &	North	3	13	14	14	15	14	14	14	14	14	14	14	13	3	South	Feb. 20 & Oct. 23
	Northeast	28	112	125	102	68	28	14	14	14	13	11	7	1	Southeast		
	East	36	140	164	149	105	48	14	14	14	13	11	7	1	East		
Apr. 20	Southeast	22	83	102	94	75	38	16	14	14	14	14	14	7	1	Northeast	
	South	1	7	11	13	16	18	19	18	18	13	11	7	1	North		
	Southwest	1	7	11	13	14	14	16	38	38	94	102	83	22	Northwest		
	West	1	7	11	13	14	14	14	48	48	149	164	140	36	West		
	Northwest	1	7	11	13	14	14	14	28	28	102	125	112	28	Southwest		
	Horizontal	3	42	106	167	212	235	249	239	212	167	106	42	3	Horizontal		
gain	steel Sash, or												Dew point				
Solar correction	No Sash												Dew point	Increase from 67°F			
	x 1/.85												+ 7% per 10°F	- 7% per 10°F			
	or 1.17																

Source: A lecture note on air conditioning design (24)

Table G.6 Equivalent Temp Difference (°F) Dark Colored Sunlit & Shaded Roof.

Correction already made for: Outdoor, Indoor temp, Daily range. This table then based on Dark colored wall, 95 °F db. Outdoor Design Temp. Constant 73 °F db room temp. 17 °F Daily range 24 hr. operation, April & 13.8°N Lat.

CONDITION	WEIGHT OF ROOF (lb/Sq.ft)	SUN TIME																																			
		AM												PM																							
		6	7	8	9	10	11	12	1	2	3	4	5	6	7	8	9	10	11	12	1	2	3	4	5	6	7	8	9	10	11	12	1	2	3	4	5
Exposed to Sun	10	-4	-3	-4	-2	2	10	19	23	37	43	48	52	49	47	41	32	27	21	14	11	7	5	3	2	11	7	5	3	2							
	20	4	3	2	4	6	13	20	28	35	41	46	49	49	46	40	35	30	25	20	16	12	10	8	6	16	12	10	8	6							
	40	8	7	6	7	10	14	21	28	33	38	43	45	47	45	40	37	33	29	25	22	16	16	13	19	22	16	16	13	19							
	60	13	12	10	11	12	15	21	27	32	36	40	44	45	44	41	39	36	33	30	27	28	21	18	15	27	28	21	18	15							
	80	18	17	15	15	17	18	21	27	31	33	37	40	43	42	40	36	39	37	35	32	28	25	23	19	32	28	25	23	19							
Covered with water	20	-2	2	4	6	8	14	20	23	26	24	22	20	18	16	14	10	6	5	5	3	2	1	.4	-2	3	2	1	.4	-2							
	40	1	2	3	3	4	9	14	13	19	19	20	19	19	18	16	14	11	9	7	5	3	2	1	1	5	3	2	1	1							
	60	3	2	2	2	2	6	9	14	18	20	22	23	23	22	20	18	16	14	12	10	8	7	6	5	10	8	7	6	5							
Sprayed	20	-4	2	4	6	8	12	16	19	22	21	20	19	18	16	14	10	6	5	4	3	2	2	1	1	3	2	2	1	1							
	40	2	2	3	3	4	6	9	13	17	18	18	18	18	17	16	18	12	9	7	5	4	4	3	3	5	4	4	3	3							
	60	3	2	2	2	2	4	6	9	12	14	16	17	18	17	16	15	14	12	10	8	6	5	4	3	8	6	5	4	3							
Shaded	20	-2	-2	-1	2	4	6	10	13	16	17	18	17	16	14	12	9	6	5	4	3	1	-1	-2	-2	3	1	-1	-2	-2							
	40	-2	-2	-1	1	2	4	6	9	12	14	16	17	16	15	14	12	10	8	6	4	3	1	-1	-2	4	3	1	-1	-2							
	60	1	1	2	2	2	3	4	6	8	10	12	13	14	14	14	13	12	10	8	6	5	4	3	2	6	5	4	3	2							
	6	7	8	9	10	11	12	1	2	3	4	5	6	7	8	9	10	11	12	1	2	3	4	5	1	2	3	4	5								
		AM												PM												AM											
		SUN TIME																																			

Source: A lecture note on air conditioning design (24)


Table G.7 Equivalent Temp Difference °F, Dark Colored Sunlit & Shaded Wall

Correction already made for outdoor, indoor temp, daily range. This table then based on dark colored wall, 95 °F db outdoor design temp, constant 78 °F db room temp, 17 °F daily range 24 hr operation, April 13.8 °N Lat.

EXPOSURE	WEIGHT OF WALL (lb/sq.ft)	SUNTIME																																			
		AM												PH												PM											
		6	7	8	9	10	11	12	1	2	3	4	5	6	7	8	9	10	11	12	1	2	3	4	5												
Northeast	20	8.5	13.5	25.5	26.0	27.5	22.5	17.5	18.5	19.5	16.5	17.5	17.5	15.5	15.5	13.5	11.5	9.5	7.5	5.5	3.5	1.5	0.5	1.5													
	60	2.5	11.5	1.5	3.5	27.5	25.5	23.5	18.5	13.5	14.5	15.5	16.5	17.5	15.5	14.5	13.5	11.5	9.5	7.5	5.5	4.5	3.5	2.5													
	100	7.5	6.5	7.5	7.5	13.5	19.5	18.5	17.5	15.5	15.5	14.5	13.5	12.5	11.5	10.5	9.5	8.5	7.5	6.5	5.5	4.5	3.5	2.5													
	140	8.5	0.5	9.5	9.5	9.5	13.5	17.5	19.5	17.5	15.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	12.5	11.5	10.5	10.5	10.5													
East	20	4.5	20.5	30.5	37.5	39.5	38.5	36.5	23.5	15.5	16.5	18.5	17.5	17.5	15.5	13.5	11.5	9.5	7.5	5.5	3.5	2.5	1.5	0.5													
	60	2.5	2.5	3.5	24.5	23.5	34.5	24.5	22.5	27.5	13.5	15.5	16.5	17.5	16.5	15.5	11.5	9.5	7.5	6.5	4.5	4.5	3.5	2.5													
	100	8.5	8.5	9.5	11.5	17.5	23.5	27.5	23.5	21.5	19.5	17.5	17.5	17.5	16.5	15.5	14.5	13.5	12.5	11.5	10.5	10.5	9.5	8.5													
	140	14.5	13.5	13.5	12.5	11.5	12.5	13.5	18.5	21.5	22.5	21.5	20.5	19.5	17.5	15.5	13.5	11.5	9.5	7.5	6.5	5.5	4.5	3.5													
Southeast	20	13.5	9.5	16.5	23.5	23.5	20.5	31.5	29.5	27.5	22.5	13.5	18.5	17.5	15.5	13.5	11.5	9.5	7.5	5.5	3.5	2.5	1.5	0.5													
	60	4.5	4.5	3.5	16.5	23.5	27.5	31.5	29.5	24.5	21.5	18.5	17.5	16.5	15.5	14.5	13.5	11.5	9.5	8.5	7.5	6.5	5.5	4.5													
	100	10.5	10.5	9.5	9.5	14.5	19.5	20.5	21.5	22.5	21.5	19.5	17.5	16.5	15.5	14.5	13.5	12.5	11.5	10.5	9.5	8.5	7.5	6.5													
	140	12.5	11.5	11.5	11.5	10.5	9.5	14.5	18.5	19.5	21.5	18.5	17.5	16.5	15.5	14.5	13.5	12.5	11.5	10.5	9.5	8.5	7.5	6.5													
South	20	2.5	1.5	-0.5	4.5	7.5	17.5	25.5	30.5	33.5	31.5	29.5	23.5	19.5	15.5	13.5	10.5	8.5	6.5	4.5	3.5	2.5	1.5	0.5													
	60	7.5	7.5	-0.5	0.5	1.5	10.5	15.5	23.5	27.5	28.5	26.5	23.5	18.5	15.5	13.5	11.5	9.5	7.5	5.5	4.5	3.5	2.5	1.5													
	100	7.5	7.5	5.5	5.5	5.5	6.5	7.5	11.5	15.5	12.5	19.5	21.5	18.5	17.5	14.5	13.5	12.5	11.5	10.5	9.5	8.5	7.5	6.5													
	140	10.5	9.5	9.5	8.5	7.5	7.5	7.5	7.5	7.5	10.5	13.5	16.5	17.5	18.5	19.5	17.5	15.5	13.5	12.5	11.5	10.5	9.5	8.5													
Southwest	20	1.5	-3.5	-0.5	1.5	3.5	7.5	9.5	28.5	29.5	37.5	43.5	44.5	45.5	33.5	27.5	15.5	9.5	7.5	5.5	4.5	3.5	2.5	1.5													
	60	5.5	4.5	3.5	3.5	3.5	4.5	5.5	11.5	15.5	27.5	35.5	38.5	39.5	37.5	23.5	13.5	10.5	9.5	8.5	7.5	6.5	5.5	4.5													
	100	10.5	3.5	9.5	8.5	7.5	7.5	9.5	10.5	11.5	15.5	17.5	22.5	25.5	26.5	27.5	26.5	25.5	19.5	13.5	12.5	11.5	10.5	9.5													
	140	11.5	11.5	11.5	11.5	10.5	10.5	9.5	9.5	9.5	10.5	11.5	12.5	13.5	18.5	21.5	22.5	23.5	16.5	11.5	11.5	11.5	11.5	11.5													
West	20	1.5	0.5	-0.5	1.5	3.5	6.5	9.5	17.5	23.5	35.5	43.5	48.5	51.5	37.5	25.5	17.5	11.5	8.5	5.5	3.5	2.5	1.5	0.5													
	60	5.5	4.5	3.5	3.5	3.5	5.5	7.5	10.5	13.5	22.5	29.5	37.5	43.5	46.5	39.5	31.5	19.5	13.5	9.5	7.5	6.5	5.5	4.5													
	100	10.5	10.5	9.5	9.5	9.5	9.5	9.5	10.5	11.5	13.5	15.5	20.5	23.5	28.5	31.5	30.5	23.5	22.5	17.5	15.5	14.5	13.5	12.5													
	140	16.5	14.5	13.5	12.5	11.5	11.5	11.5	12.5	13.5	13.5	14.5	15.5	17.5	19.5	21.5	25.5	25.5	26.5	23.5	23.5	19.5	18.5	16.5													
Northwest	20	0.5	-0.5	-0.5	0.5	3.5	6.5	9.5	13.5	15.5	27.5	36.5	43.5	40.5	37.5	21.5	19.5	9.5	5.5	3.5	2.5	1.5	0.5	1.5													
	60	1.5	0.5	-0.5	0.5	1.5	3.5	5.5	9.5	11.5	23.5	33.5	34.5	35.5	21.5	15.5	11.5	8.5	6.5	4.5	3.5	2.5	1.5	0.5													
	100	3.5	7.5	7.5	7.5	7.5	7.5	8.5	8.5	8.5	8.5	12.5	15.5	20.5	23.5	24.5	25.5	17.5	11.5	10.5	9.5	8.5	7.5	6.5													
	140	11.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5	10.5	11.5	12.5	13.5	17.5	21.5	23.5	23.5	19.5	16.5	14.5	13.5	12.5													
North (Shade)	20	0.5	-0.5	0.5	-0.5	1.5	4.5	7.5	11.5	13.5	15.5	17.5	16.5	15.5	13.5	11.5	9.5	7.5	5.5	3.5	2.5	1.5	1.5	0.5													
	60	0.5	0.5	-0.5	-0.5	1.5	2.5	3.5	5.5	6.5	9.5	11.5	14.5	15.5	15.5	12.5	11.5	9.5	7.5	5.5	4.5	3.5	2.5	1.5													
	100	4.5	3.5	3.5	3.5	3.5	3.5	4.5	4.5	4.5	4.5	6.5	8.5	8.5	8.5	11.5	10.5	9.5	8.5	7.5	6.5	5.5	4.5	3.5													
	140	4.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	4.5	5.5	6.5	7.5	8.5	9.5	10.5	11.5	10.5	9.5	8.5	7.5	6.5													
		6	7	8	9	10	11	12	1	2	3	4	5	6	7	8	9	10	11	12	1	2	3	4	5												
AM												PM												AM													

## Appendix H

Figure H.1 The Revised ASHRAE Comfort Chart



The ASHRAE Comfort Chart indicates the effect of different air temperatures and humidities on comfort. Studies showed little effect of humidity except at quite high humidities.



## APPENDIX I

### SOME DETAILED CALCULATIONS FOR THE THERMAL SYSTEM

In this Appendix, the determination procedures for heat input to the boiler, heat output of the boiler, and steam requirement for each piece of equipment are illustrated.

#### I.1 Determination of Heat Input to the Boiler

##### 1.1 Chemical heat in the fuel "as fired,"

$$Q_{fc} = (W_f)(H_1)$$

where  $W_f$  = measured fuel rate, kg per hr;

$H_1$  = low-heating value, kcal per hr.

For this combustion chamber with the data obtained, we get

$$Q_{fc} = 1,732,500 \text{ kcal per hour.}$$

##### 1.2 Heat credit supplied by feedwater,

$$Q_w = (W_w)(C_{pw})(t_{fw} - t_i)$$

where  $W_w$  = feedwater flow rate, kg per hr;

$C_{pw}$  = specific heat of feedwater, kcal per kg °C;

$t_{fw}$  = intake feedwater temperature, °C;

$t_i$  = reference temperature, 30 °C.

For the feedwater with the data obtained, we find  $Q_w$  is equal 156,900 kcal per hour.



1.3 Heat credit supplied by preheated fuel oil,

$$Q_{fp} = (W_f)(C_f)(t_f - t_i)$$

where  $C_f$  = specific heat of fuel oil, kcal per kg °C;

$t_f$  = temperature of fuel before combustion, °C;

other symbols as before.

For this fuel oil with the data obtained, we get  $Q_{fp}$  equal 5481 kcal per hour.

## I.2 Computation for the Output of the Boiler

2.1 Heat of steam produced,  $Q_s = W_s(h_2 - h_1)$ , where  $W_s$  = net quantity of steam produced, kg per hr;  $h_2$  = enthalpy\* of steam leaving the boiler, kcal per kg;  $h_1$  = enthalpy of water at reference temperature (30°C), kcal per kg. Here, we have  $W_s = 2715$ ,  $h_2 = 638.8$  (assume the steam quality be 0.95), and  $h_1 = 30$ . Then,  $Q_s = 1,652,892$  kcal per hour.

2.2 Heat loss due to dry flue gas:

For any boiler the dry-flue gas loss  $Q_g$  kcal per hour is given by  $Q_g = G.C_g.(t_g - t_i)$ , where  $G$  = the amount of flue-gas, Nm<sup>3</sup> per kg of fuel;  $C_g$  = average specific heat of dry-flue gas, kcal per Nm<sup>3</sup>·°C;  $t_g$  = flue-gas exit temperature, °C;  $t_i$  is as given previously.

To find  $G$ , we proceed as follows:

2.2.1 The air required by actual combustion,  $A = m.A_0$  where  $A_0$  = air required for complete combustion or theoretical air, Nm<sup>3</sup> per kg of fuel;  $m$  = excess air coefficient or air ratio. Using a

---

\* For this calculation, assume that the steam quality is 0.95.

formula suggested by Boie (9) and typical inspection values for the heavy fuel oil provided by the ESSO Standard Thailand Ltd,

$$A_o = \frac{12.38(H_1 - 1100)}{10000} \quad \text{or } 10.89 \text{ Nm}^3 \text{ per kg of fuel when } H_1 \text{ represents}$$

the low-heat value of 9900 Kcal per kg of fuel oil. The air ratio, on the other hand, may be calculated by  $m = \frac{(\text{CO}_2)_{\text{max}}}{(\text{CO}_2)}$ , where  $(\text{CO}_2)_{\text{max}}$  is the volume fraction of carbon dioxide found from laboratory analysis.

For fuel oil, this value is approximately 15.7 percent.\* Since the measured percentage of  $\text{CO}_2$  is 12.5,\*\* the air ratio may be calculated as 1.256. Then,  $A = 1.256 \times 10.87 = 13.68 \text{ Nm}^3$  per kg of fuel.

$$2.2.2 \quad \text{The amount of dry flue-gas, } G = G_o + (m-1) A_o,$$

where  $G_o$  = theoretical dry flue-gas and may be estimated by a formula

$$\text{of Boie (9) as } G_o = \frac{15.75(H_1 - 1100)}{10000} - 2.18 \text{ or } 11.68 \text{ Nm}^3 \text{ per kg of fuel.}$$

With this  $G_o$ , together with  $m$  and  $A_o$  found in 2.2.1,  $G = 14.47 \text{ Nm}^3$  per kg of fuel.

Then, with  $G = 14.47 \text{ Nm}^3$  per kg of fuel,  $C_g = 0.332$  kcal per  $\text{Nm}^3 \text{ }^\circ\text{C}$ ,  $t_g = 232 \text{ }^\circ\text{C}$ , and  $t_i = 30 \text{ }^\circ\text{C}$ , the dry-flue gas loss is 169,824 kcal per hour for the given firing rate.

2.3 Heat loss due to blowdown,  $Q_b = W_b C_b (t_b - t_i)$ , where  $W_b$  = quantity of blow, kg per hour;  $C_b$  = specific heat of blow water, kcal per  $\text{kg }^\circ\text{C}$ ;  $t_b$  = temperature of the blowing water,  $^\circ\text{C}$ ; and  $t_i$  as before. With the data obtained,  $Q_b = 62,878$  kcal per hour.

---

\* See Table 2.18, pp. 47 of the Thermal Energy Conservation Handbook (9).

\*\* Data measured on a typical day of November 1985.

### I.3 Determination of Steam Consumption at Various Equipment

#### 1. The Melting Tank

Caprolactam, 90% from the crush mill and 10% from the recovered lactam storage tank, is fed into the melting tank where a low pressure steam is supplied to its steam jacket to melt the material.

A simplified diagram of this system is exhibited in Figure I.1.




Figure I.1 Flow Diagram of the Melting Tank.

Applying the first law of thermodynamics to the tank,

$$\dot{m}_s q_s + W - Q = 0.9 \dot{m}_1 C_1 (T_1 - T_1) + \dot{m}_1 L_1$$

where  $\dot{m}_s, \dot{m}_1, 0.9 \dot{m}_1$  = mass flow rate of steam, molten lactam and new lactam, respectively, kg/hr

$q_s$  = specific enthalpy of vaporization, kcal/kg

$W$  = electrical energy for the agitator, kcal/hr

$Q$  = heat loss from the tank, kcal/hr

$C_1$  = specific heat of solid lactam

$T_1, T_1$  = melting point of lactam, room temperature

$L_1$  = latent heat of solid lactam

yield  $\dot{m}_s = 57 \text{ kg/hr.}$

## 2. The Blending Tank

The molten caprolactam from the melting tank is transferred, batch by batch, into the blending tank in which water, acetic acid, as well as titanium dioxide are introduced. The system may be shown as Figure I.2.




Figure I.2 Flow Diagram of the Blending Tank.

Applying the first law of thermodynamics to the blending tank,

$$\dot{m}_s q_s + W - Q = \dot{m}_w C_w (T_w - T_1)$$

where  $\dot{m}_w, C_w, T_w =$  mass flow rate, specific heat, inlet water temperature of water and other symbols are the same as those described for the melting tank, we get  $\dot{m}_s = 3.0 \text{ kg/hr.}$

## 3. The Extraction Tower

After screening process, see Figure 3.2 and 3.3 the raw chip will be blown through a vertical pipe, via a channel at the upper zone, into the extraction tower. After that, lactam of about 11% of the raw chip, dissolved by circulating water, will be discharged to the wash-water collection tank while other 89%, in polymer form, is

discharged to the wet chip storage bins. Figure I.3 exhibits the tower with three lines of low pressure steam.




Figure I.3 Flow Diagram of the Extraction Tower.

By measuring condensate from the three steam traps, the total steam requirement of this tower is 129 kg/hr. Since there are two identical production lines, the amount of steam for this system may be calculated as 258 kg/hr.

#### 4. The Evaporation System

Steam consumption in this system is that required by the first effect heat exchanger, by the steam ejector of the second effect, by the distillation kettle, and by steam ejectors of the distillation kettle. Descriptions for each item will be given as follows:





#### 4.1 The First Effect Heat Exchanger

The following figure illustrates the system under consideration.




Figure I.4 Flow Diagram of the First Effect.

Applying the first law of thermodynamics to this system,

$$\dot{m}_s q_s + W - Q = -\dot{m}_w C_w (T_{11} - 30) + \dot{m}_v (C_w (T_v - 30) + L_w) + (\dot{m}_w - \dot{m}_v) h + \dot{m}_m C_m (T_{12} - T_{11})$$

where  $L_w$  = heat of water vaporization, kcal/kg

$\dot{m}_v$  = mass flow rate of vapor, kg/hr.

$C_m$  = specific heat of monomer, kcal/kg °C

$h$  = specific enthalpy of saturated water, kcal/kg

and other symbols as before, we get  $\dot{m}_s = 766$  kg per hr.

#### 4.2 The Steam Ejector of the Second Effect

This ejector is of single stage. Calculations for steam requirement can be made by the procedure given in the Pumping of Liquids and Gases (19), pages 6-29 to 6-34. An illustration of this system is shown by the following figure.




Figure I.5 Flow Diagram of the Single Stage Ejector.

In this figure,  $p_{o3}$  = discharge pressure = 760 Torr,  $p_{oa}$  = motive gas pressure = 9 kg per  $\text{cm}^2$  g, and  $p_{ob}$  = suction pressure = 623 Torr. Enters the chart, see Figure I.6\*, with  $p_{o3}/p_{ob} = 760/623 = 1.22$  and  $p_{ob}/p_{oa} = 623/(9 \times 760) = 0.091$  to obtain the optimum area ratio,  $A_2/A_t = 60$ . Proceeding horizontally to the left, we find that  $w_b/w_a$ , mass ratio, is approximately 5.5 kg of air per kg of steam. This value, however, must be corrected for temperature and molecular weight differences of the two fluids, vapor and steam, by the equation  $\left(\frac{w_b}{w_a}\right)' = \frac{w_b}{w_a} \sqrt{\frac{T_{oa} M_b}{T_{ob} M_a}}$ , where  $T_{oa}$  = temperature of steam = 179°C,  $T_{ob}$  = temperature of vapor = 94.4°C, and  $M_a$  and  $M_b$  are molecular weights of steam and vapor, respectively, which are assumed to be equal. Therefore,  $\left(\frac{w_b}{w_a}\right)' = 7.57$  or the steam flow rate,  $w_a' = \frac{725.92}{7.57} = 96$  kg per hr.

\* This figure is Figure 6.72 in the Pumping of Liquids and Gases (19)




Figure I.6 Optimum Design Curves for Single-Stage Ejectors.

### 4.3 The Distillation Kettle

In this system, a batch of mixture with 55% monomer weighs 6100 kg is distilled until caprolactam of 2000 kg is obtained. A flow diagram of this equipment is illustrated in Figure I.7.




Figure I.7 Flow Diagram of the Distillation Kettle.

Applying the first law of thermodynamics to the kettle,

$$\dot{m}_s q_s - Q = \frac{1}{t} \left[ \dot{m}_w \left\{ C_w (T_{r1} - T_{mx}) + L_w \right\} + \dot{m}_{lo} \left\{ C_{lo} (T_{r2} - T_{mx}) + L_{lo} \right\} + m_k C_k (T_{r2} - T_i) \right],$$

where  $t$  = cycle time or batch time, hr;  $T_{r1}$ ,  $T_{r2}$  = temperature of recovered lactam at the first and second stage, respectively, °C;

$T_{mx}$  = temperature of the mixture of lactam, oligomer and water, °C;

$L_w$  = heat of water vaporization, kcal per kg;  $\dot{m}_{lo}$  = mass flow rate of lactam and oligomer, kg per hr;  $C_{lo}$  = specific heat of lactam and oligomer, kcal per kg °C;  $L_{lo}$  = heat of lactam vaporization, kcal per

kg;  $m_k$  = mass of the kettle, kg;  $C_k$  = specific heat of the kettle,

kcal per kg °C, and other symbols are as before. Therefore, steam

consumption for the process at this equipment,  $m_s$ , is approximately 98 kg per hr.

#### 4.4 Steam Ejectors of the Distillation Kettle

This equipment has a two-stage ejector with suction pressure of 10 Torr and requires steam pressure of 9 kg per  $\text{cm}^2$  g. The operating cycle at this process is 48 hr, 33 hr of actual operation and 15 hr of idle time. A flow diagram for this equipment is exhibited in Figure I.8.




Figure 1.8 Flow Diagram of the Two-Stage Ejector with an Inter-Condenser.



An estimation was done to find steam consumption of this equipment using the performance curve and table provided by Roger G. Mote in his study of the Jet Ejectors and Condensers as Vacuum Producing Devices which is published in Chapter 5 of the Process Equipment Series Volume 3 (20).\*

By this method, steam requirement of this equipment is 124 kg per hr.

#### 5. The Vacuum Dryers

Four sets of the dryer have been employed for the manufacturing process. Each dryer consists of a dryer drum and a three-stage ejector consuming steam of 9 kg per cm<sup>2</sup> g. The overall operating cycle is 24 hours including 8 hours of two-stage ejector running at 40 Torr suction pressure, 7 hours of three-stage ejector at 5 Torr suction pressure, and 9 hours of idle time waiting for the next batch of material to come. A simplified diagram representing this group of equipment is shown in Figure I.9.

---

\* As indicated in the curves, Figure 5.45 and 5.46 of the stated reference, the suction pressure of 10 Torr corresponds to the zone of TABLE A in Figure 5.45. For steam pressure of 9 kg per cm<sup>2</sup> g and capacity factor of 4.0, assumed for the highest capacity, Figure 5.46 gives steam motive requirements of about 180.5 kg per hr. Then, steam consumption of this equipment averaged for the cycle time of 48 hr, with 33 hr of actual operation, is  $180.5 \times \frac{33}{48} = 124$  kg per hr.




Figure I.9 Flow Diagram of the Dryer and Its Ejector System

At the dryer, a batch of wet chip of 3000 kg with 10% moisture content is transferred from the wet chip storage bin (see Figure 3.2). The drying process continues until the final moisture content of 0.02% is attained. This process requires the two-stage ejector to obtain the moisture level of 1.0% and the three-stage to obtain the rest.

Calculation for steam consumption of the dryer (excluding the ejector system) may be accomplished by applying the first law of thermodynamics,

$$\dot{m}_s q_s + W - Q = \frac{1}{24} m_d C_d (T_d - T_i) + 0.9 \dot{m}_c C_c (T_d - T_i) + 0.0998 \dot{m}_c [(C_w (T_d - T_i) + L_w)]$$

where  $W$  = electric energy for the dryer motor,  $m_d$  = mass of the dryer,  $C_d$  = specific heat of the dryer,  $T_d$  = final temperature of




Figure I.10 Operating Curves for Estimating Steam Requirement of Ejectors.

drying process,  $\dot{m}_c$  = mass flow rate of the chip,  $C_c$  = specific heat of the chip, and other symbols as before. Then, steam requirement of the dryer, excluding the ejector system, is 39.8 kg per hr.

The steam requirement of the evaporator air pump (ejector), on the other hand, can be determined indirectly using the chart given in Figure I.10.\*

For the four sets of vacuum dryers of the manufacturing process, the total amount of steam requirement is  $4 \times (39.8 + 161.5) = 805$  kg per hr.

#### 6 The Finishing Tower Steam Ejectors

There are two sets of single-stage steam ejector installed for the two finishing towers to pump out their dowterm vapor. Using the result found in 4.2, steam required by the FNT ejectors is approximately  $2 \times 95.89 = 192$  kg per hr.

---

\* This is the chart given in Figure 4,2a on page 50 of the High Vacuum Pumping Equipment (21). Referring to this figure, with the suction pressure of 40 Torr for the two-stage ejector and of 5 Torr for the three-stage one, the volumetric speed of 278 and 236 kg per hr, respectively, are obtained. Using these two figures as steam estimates for the two operations, the average steam consumption for the ejector system is  $(8 \times 278 + 7 \times 236)/24 = 161.5$  kg per hr.

### 7. The Take-Up Air Washer

Steam is utilized by the air washer to control the relative humidity of cooling air as described in chapter 6. The steam flow rate into this equipment is easily measured by its condensate flowing out. A measurement taken in late January 1986 indicated that the steam flow rate was about 122 kg per hr.

### 8. The Take-Up Finish Oil Tank

There are two types of fiber being produced in the factory, 40/10 and 70/10, each of which requires difference mixture of finish oil.

Steam is used to raise the temperature of each mixture from 20°C to 50°C. The heat load of this system is approximately  $(3 \dot{m}_1 + 2 \dot{m}_2) \cdot (C_m)(50-20)$ , where  $\dot{m}_1$  and  $\dot{m}_2$  are mass flow rate, kg per hr, of the mixture for the two types of fiber;  $C_m$  is specific heat of each mixture, in this case, assumed to be 1 kcal per kg°C. With pressure of 2 kg per  $\text{cm}^2$ , the steam consumed by this tank is 4 kg per hr.

### 9. The Deaerator

Steam is used in this equipment to eliminate  $\text{O}_2$ ,  $\text{CO}_2$ ,  $\text{H}_2\text{S}$ , and other gases in feedwater. Based on data in Table 7.1, the steam required by this process is 298 kg per hr.

### 10. The Oil Preheater

Heavy fuel oil from the storage tank is preheated first by steam flashed from the blowdown to raise its temperature upto about 40°C and then by boiler's steam and electric heater. The oil temperature after the two latter heat sources is about 110°C. A flow diagram at the preheater may be illustrated as follows.






Figure I.11 Flow Diagram of the Oil Preheater.

Applying the first law of thermodynamics to the preheater

$$\dot{m}_s q_s - Q = \dot{m}_f C_f (T_{f2} - T_{f1}),$$

where  $\dot{m}_f$ ,  $C_f$ ,  $T_{f1}$  and  $T_{f2}$  are mass flow rate (kg/hr), specific heat (kcal/kg°C), inlet temperature (°C), and outlet temperature (°C), respectively, of the fuel oil; other symbols as before. The steam consumption of this preheater of about 16 kg per hr is estimated.

#### 11. The Burn Out Furnace

The furnace has been used to clean the spinnerette and accessories of process equipment. The quantity of steam sprayed into this burner can be estimated by  $\dot{m}_s = 900 \pi \gamma d^2 u$ , where  $\dot{m}_s$  = steam flow rate, kg per hr;  $\gamma$  = specific gravity of steam, kg per m<sup>3</sup>;  $d$  = inner diameter of the pipe, m; and  $u$  = steam velocity in the pipe, pipe, m per sec. With  $\gamma = 5.053$  kg per m<sup>3</sup>,  $d = 0.0127$  m,  $u = 20$  m per sec, from Table 5.3 of the Thermal Energy Conservation Handbook (9), steam flow rate is 46 kg per hr. Since the furnace runs 4 hours per day, steam consumption is approximately 8 kg per hr.

Table I.1 Properties of Saturated Steam

Pressure P (kg/cm <sup>2</sup> )	Temperature (°C)	Volume (m <sup>3</sup> /kg)		Enthalpy (kcal/kg)			Entropy (kcal/kg °K)	
		v'	v''	h'	h''	r	s'	s''
1.0	99.09	0.0010430	1.725	99.17	638.8	539.6	0.3097	1.7594
1.033	100.00	0.0010437	1.673	100.09	639.2	539.1	0.3121	1.7568
1.2	104.25	0.0010471	1.454	104.37	640.7	536.4	0.3235	1.7448
1.4	108.74	0.0010508	1.259	108.91	642.4	533.5	0.3355	1.7324
1.6	112.73	0.0010542	1.111	112.94	643.8	530.8	0.3460	1.7217
1.8	116.33	0.0010573	0.9952	116.59	645.0	528.5	0.3554	1.7122
2.0	119.61	0.0010603	0.9018	119.92	646.2	526.3	0.3639	1.7038
2.2	122.64	0.0010631	0.8249	123.00	647.2	524.2	0.3717	1.6961
2.6	128.08	0.0010682	0.7053	128.53	649.0	520.5	0.3855	1.6828
3.0	132.88	0.0010728	0.6168	133.42	650.9	517.2	0.3976	1.6713
4	142.92	0.0010831	0.4708	143.70	653.7	510.0	0.4226	1.6483
5	151.11	0.0010920	0.3816	152.13	656.0	503.9	0.4426	1.6303
6	158.08	0.0011000	0.3213	159.34	657.9	498.6	0.4594	1.6156
7	164.17	0.0011072	0.2778	165.67	659.5	493.8	0.4739	1.6031
8	169.61	0.0011140	0.2448	171.35	660.8	489.5	0.4867	1.5922
9	171.45	0.0011203	0.2183	176.51	661.9	485.4	0.4983	1.5826
10	179.04	0.0011262	0.1979	181.25	662.9	481.7	0.5087	1.5739
11	183.20	0.0011319	0.1807	185.65	663.7	478.1	0.5184	1.5660
12	187.08	0.0011373	0.1663	189.77	664.5	474.7	0.5273	1.5588
13	190.71	0.0011425	0.1540	193.63	665.1	471.5	0.5356	1.5521
14	194.13	0.0011476	0.1434	197.29	665.7	468.4	0.5434	1.5468
15	197.37	0.0011524	0.1342	200.75	666.2	465.5	0.5507	1.5410
16	200.43	0.0011572	0.1260	204.05	666.7	462.6	0.5577	1.5345
17	203.36	0.0011618	0.1189	207.21	667.1	459.9	0.5642	1.5293
18	206.15	0.0011663	0.1124	210.23	667.4	457.2	0.5705	1.5244
19	208.82	0.0011706	0.1067	213.14	667.7	454.6	0.5765	1.5197
20	221.39	0.0011749	0.1015	215.94	668.0	452.1	0.5822	1.5152

Table 1.2 1 % Interest Factors for Discrete Compounding Periods.

N	SINGLE PAYMENT		UNIFORM PAYMENT SERIES				GRADIENT SERIES	
	Compound Amount Factor	Present Worth Factor	Present Worth Factor	Capital Recovery Factor	Compound Amount Factor	Sinking Fund Factor	Gradient Uniform Series	Gradient Present Worth
	Find F Given P F/P	Find P Given F P/F	Find P Given A P/A	Find A Given P A/P	Find F Given A F/A	Find A Given F A/F	Find A Given G A/G	Find P Given G P/G
1	1.010	0.9901	0.9901	1.0100	1.000	1.0000	0.0000	0.000
2	1.020	0.9803	1.9704	0.5075	2.010	0.4975	0.4975	0.980
3	1.030	0.9706	2.9410	0.3400	3.030	0.3300	0.9934	2.921
4	1.041	0.9610	3.9020	0.2563	4.060	0.2463	1.4876	5.804
5	1.051	0.9515	4.8534	0.2060	5.101	0.1960	1.9801	9.610
6	1.062	0.9420	5.7955	0.1725	6.152	0.1625	2.4710	14.321
7	1.072	0.9327	6.7282	0.1486	7.214	0.1386	2.9602	19.917
8	1.083	0.9235	7.6517	0.1307	8.286	0.1207	3.4478	26.381
9	1.094	0.9143	8.5660	0.1167	9.369	0.1067	3.9337	33.696
10	1.105	0.9053	9.4713	0.1056	10.462	0.0956	4.4179	41.843
11	1.116	0.8963	10.3676	0.0965	11.567	0.0865	4.9005	50.807
12	1.127	0.8874	11.2551	0.0888	12.683	0.0788	5.3815	60.569
13	1.138	0.8787	12.1337	0.0824	13.809	0.0724	5.8607	71.113
14	1.149	0.8700	13.0037	0.0769	14.947	0.0669	6.3384	82.422
15	1.161	0.8613	13.8651	0.0721	16.097	0.0621	6.8143	94.481
16	1.173	0.8528	14.7179	0.0679	17.258	0.0579	7.2886	107.273
17	1.184	0.8444	15.5623	0.0643	18.430	0.0543	7.7613	120.783
18	1.196	0.8360	16.3983	0.0610	19.615	0.0510	8.2323	134.996
19	1.208	0.8277	17.2260	0.0581	20.811	0.0481	8.7017	149.895
20	1.220	0.8195	18.0456	0.0554	22.019	0.0454	9.1694	165.466
21	1.232	0.8114	18.8570	0.0530	23.239	0.0430	9.6354	181.695
22	1.245	0.8034	19.6604	0.0509	24.472	0.0409	10.0998	198.566
23	1.257	0.7954	20.4558	0.0489	25.716	0.0389	10.5626	216.066
24	1.270	0.7876	21.2434	0.0471	26.973	0.0371	11.0237	234.180
25	1.282	0.7798	22.0232	0.0454	28.243	0.0354	11.4831	252.894
26	1.295	0.7720	22.7952	0.0439	29.526	0.0339	11.9409	272.196
27	1.308	0.7644	23.5596	0.0424	30.821	0.0324	12.3971	292.070
28	1.321	0.7568	24.3164	0.0411	32.129	0.0311	12.8516	312.505
29	1.335	0.7493	25.0658	0.0399	33.450	0.0299	13.3044	333.486
30	1.348	0.7419	25.8077	0.0387	34.785	0.0287	13.7557	355.002
31	1.361	0.7346	26.5423	0.0377	36.133	0.0277	14.2052	377.039
32	1.375	0.7273	27.2696	0.0367	37.494	0.0267	14.6532	399.586
33	1.389	0.7201	27.9897	0.0357	38.869	0.0257	15.0995	422.629
34	1.403	0.7130	28.7027	0.0348	40.258	0.0248	15.5441	446.157
35	1.417	0.7059	29.4086	0.0340	41.660	0.0240	15.9871	470.158
36	1.431	0.6989	30.1075	0.0332	43.077	0.0232	16.4285	494.621
37	1.445	0.6920	30.7995	0.0325	44.508	0.0225	16.8682	519.533
38	1.460	0.6852	31.4847	0.0318	45.953	0.0218	17.3063	544.884
39	1.474	0.6784	32.1630	0.0311	47.412	0.0211	17.7428	570.662
40	1.489	0.6717	32.8347	0.0305	48.886	0.0205	18.1776	596.856

Table 1.3 12 % Interest Factors for Discrete Compounding Periods.

N	SINGLE PAYMENT		UNIFORM PAYMENT SERIES			GRADIENT SERIES		
	Compound Amount Factor	Present Worth Factor	Present Worth Factor	Capital Recovery Factor	Compound Amount Factor	Sinking Fund Factor	Gradient Uniform Series	Gradient Present Worth
	Find F Given P F/P	Find P Given F P/F	Find P Given A P/A	Find A Given P A/P	Find F Given A F/A	Find A Given F A/F	Find A Given G A/G	Find P Given G P/G
1	1.120	0.8929	0.8929	1.1200	1.000	1.0000	0.0000	0.000
2	1.254	0.7972	1.6901	0.5917	2.120	0.4717	0.4717	0.797
3	1.405	0.7118	2.4018	0.4163	3.374	0.2963	0.9246	2.221
4	1.574	0.6355	3.0373	0.3292	4.779	0.2092	1.3589	4.127
5	1.762	0.5674	3.6048	0.2774	6.353	0.1574	1.7746	6.397
6	1.974	0.5066	4.1114	0.2432	8.115	0.1232	2.1720	8.930
7	2.211	0.4523	4.5638	0.2191	10.089	0.0991	2.5515	11.644
8	2.476	0.4039	4.9676	0.2013	12.300	0.0813	2.9131	14.471
9	2.773	0.3606	5.3282	0.1877	14.776	0.0677	3.2574	17.356
10	3.106	0.3220	5.6502	0.1770	17.549	0.0570	3.5847	20.254
11	3.479	0.2875	5.9377	0.1684	20.655	0.0484	3.8953	23.129
12	3.896	0.2567	6.1944	0.1614	24.133	0.0414	4.1897	25.952
13	4.363	0.2292	6.4235	0.1557	28.029	0.0357	4.4683	28.702
14	4.887	0.2046	6.6282	0.1509	32.393	0.0309	4.7317	31.362
15	5.474	0.1827	6.8109	0.1468	37.280	0.0268	4.9803	33.920
16	6.130	0.1631	6.9740	0.1434	42.753	0.0234	5.2147	36.367
17	6.866	0.1456	7.1196	0.1405	48.884	0.0205	5.4353	38.697
18	7.690	0.1300	7.2497	0.1379	55.750	0.0179	5.6427	40.908
19	8.613	0.1161	7.3658	0.1358	63.440	0.0158	5.8375	42.998
20	9.646	0.1037	7.4694	0.1339	72.052	0.0139	6.0202	44.968
21	10.804	0.0926	7.5620	0.1322	81.699	0.0122	6.1913	46.819
22	12.100	0.0826	7.6446	0.1308	92.503	0.0108	6.3514	48.554
23	13.552	0.0738	7.7184	0.1296	104.603	0.0096	6.5010	50.178
24	15.179	0.0659	7.7843	0.1285	118.155	0.0085	6.6406	51.693
25	17.000	0.0588	7.8431	0.1275	133.334	0.0075	6.7708	53.105
26	19.040	0.0525	7.8957	0.1267	150.334	0.0067	6.8921	54.418
27	21.325	0.0469	7.9426	0.1259	169.374	0.0059	7.0049	55.637
28	23.884	0.0419	7.9844	0.1252	190.699	0.0052	7.1098	56.767
29	26.750	0.0374	8.0218	0.1247	214.583	0.0047	7.2071	57.814
30	29.960	0.0334	8.0552	0.1241	241.333	0.0041	7.2974	58.782
31	33.555	0.0298	8.0850	0.1237	271.293	0.0037	7.3811	59.676
32	37.582	0.0266	8.1116	0.1233	304.848	0.0033	7.4586	60.501
33	42.092	0.0238	8.1354	0.1229	342.429	0.0029	7.5302	61.261
34	47.143	0.0212	8.1566	0.1226	384.521	0.0026	7.5965	61.961
35	52.800	0.0189	8.1755	0.1223	431.663	0.0023	7.6577	62.605
36	59.136	0.0169	8.1924	0.1221	484.463	0.0021	7.7141	63.197
37	66.232	0.0151	8.2075	0.1218	543.599	0.0018	7.7661	63.741
38	74.180	0.0135	8.2210	0.1216	609.831	0.0016	7.8141	64.239
39	83.081	0.0120	8.2330	0.1215	684.010	0.0015	7.8582	64.697
40	93.051	0.0107	8.2438	0.1213	767.091	0.0013	7.8988	65.116



## BIO-DATA

Mr. Sanguan Taungbodhitham received his Bachelor's Degree in Industrial Engineering from Prince of Songkla University in 1979.

He had attended Chulalongkorn University for his graduate study since June 1984 and completed his Master's Degree in Industrial Engineering in October 1986.

He has been working as an instructor at the department of Industrial Engineering, Prince of Songkla University since April 1979.

